

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Santafe Tile Corporation 8825 NW 95 Street Medley, FL. 33178

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami Dade-County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Artisan Blend – Handmade Barrel Clay Roof Tile

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 12-1210.03 and consists of pages 1 through 5. The submitted documentation was reviewed by Gaspar J Rodriguez.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 15-1026.03 Expiration Date: 05/09/18 Approval Date: 01/28/16

Page 1 of 5

ROOFING ASSEMBLY APPROVAL

Category: Roofing

Sub Category: Roofing Tiles

Material: Clay

1. SCOPE

This approves a roofing system using **Artisan Blend – Handmade Barrel Clay Roof Tile** manufactured by **Ceramica Andina** in **Cucuta, Colombia** and is distributed by **Santafe Tile Corporation**, as described in Section 2 of this Notice of Acceptance. For locations where the pressure requirements, as determined by applicable Building Code, do not exceed the design pressure values obtained by calculations in compliance with RAS 127 using the values listed in section 4 herein. The attachment calculations shall be done as a moment based system.

2. PRODUCT DESCRIPTION

Manufactured by Applicant	Dimensions	Test Specifications	Product Description
Applicant	Difficusions		<u>Description</u>
Artisan Blend – Handmade	L = 18"	ASTM C1167	High profile two-piece tapered clay roof tile. For
Barrel Tile	W = 9"	Type 1	direct deck, adhesive set applications.
	Thickness: 0.55"	Grade 3	
Trim Pieces	Length: varies Width: varies varying thickness	ASTM C1167	Accessory trim, clay roof pieces for use at hips, rakes, ridges and valley terminations manufactured for each tile profile.

2.1 Manufacturing Location

2.1.1. Cucuta, Colombia

2.2 EVIDENCE SUBMITTED

Test Agency	<u>Test Identifier</u>	Test Name/Report	<u>Date</u>
American Test Lab of South Florida	RT1026.01-12A	ASTM C 1167	11/02/12
	RT1116.01-12	TAS 101	11/16/12



NOA No.: 15-1026.03 Expiration Date: 05/09/18 Approval Date: 01/28/16

Page 2 of 5

3. **LIMITATIONS:**

- **3.1** Fire classification is not part of this acceptance.
- For mortar or adhesive set tile applications, a static field uplift test in accordance with TAS 106 shall be required in the HVHZ, refer to applicable building code.
- 3.3 Applicant shall retain the services of a Miami-Dade County Certified Laboratory to perform quarterly test in accordance with TAS 112, appendix 'A'. Such testing shall be submitted to the Miami-Dade County Product Control Section for review.
- 3.4 Minimum underlayment shall be in compliance with the applicable Roofing Applications Standards listed section 4.1 herein.
- 3.5 30/90 hot mopped underlayment applications may be installed perpendicular to the roof slope unless stated otherwise by the underlayment material manufacturers published literature.
- This acceptance is for wood deck applications. Minimum deck requirements shall be in compliance with 3.6 applicable building code.

4. INSTALLATION

- **4.1** Clay Barrel Tile and its components shall be installed in strict compliance with Roofing Application Standard RAS-120.
- **4.2** Data For Attachment Calculations.

Table 1: Average Weight (W) and Dimensions (I x w)			
Tile Profile	Weight-W (lbf)	Length-I (ft)	Width-w (ft)
Artisan Blend – Handmade Barrel Tile	6.5	1.5	0.75

Table 2: Aerodynamic Multipliers - λ (ft³)			
Tile Profile	λ (ft³) Batten Application	λ (ft³) Direct Deck Application	
Artisan Blend – Handmade Barrel Tile	N/A	0.23	

Table 3: Restoring Moments due to Gravity - Mg (ft-lbf)						
Tile Profile	2":12"	3":12"	4":12"	5":12"	6":12"	7":12" or Greater
Artisan	Direct Deck					
Blend – Handmade Barrel Tile	3.98	3.93	3.87	3.78	3.69	3.59



NOA No.: 15-1026.03 Expiration Date: 05/09/18 Approval Date: 01/28/16

Page 3 of 5

Table 6: Attachment Resistance Expressed as a Moment - M _f (ft-lbf) for Single Patty Adhesive Set Systems			
Tile Profile	Tile Application	Minimum Attachment Resistance	
Artisan Blend – Handmade Barrel Tile	3M [™] 2-Component Foam Roof Tile Adhesive AH-160	66.1 ¹	
1 Medium paddy placement weight 35 grams of 3M [™] 2-Component Foam Roof Tile Adhesive AH-160 for the pan tiles. 18.9g on each side of the cap tiles.			

5. LABELING

5.1 All tiles shall bear the imprint or identifiable marking of the manufacturer's name or logo as detailed below, or following statement: "Miami-Dade County Product Control Approved".



LABEL FOR ARTISAN BLEND – HANDMADE BARREL TILE (LOCATED ON THE TOPSIDE OF TILE)

6. BUILDING PERMIT REQUIREMENTS:

- **6.1** Application for building permit shall be accompanied by copies of the following:
 - **6.1.1** This Notice of Acceptance.
 - **6.1.2** Any other documents required by Building Official or Applicable building code in order to properly evaluate the installation of this system.



NOA No.: 15-1026.03 Expiration Date: 05/09/18 Approval Date: 01/28/16

Page 4 of 5

PROFILE DRAWING




Product Technical Data Sheet


Product Name: Artisan Blend - Handmade Barrel tile

Texture: Rustic Color: Red Blend

Heigh 1	2.36"
Heigh 2	2.83"
Length	18"
Width 1	7"
Width 2	9"
Thickness	0.55"
Weight	6.83 lbs







Pieces Per Square 180

ARTISAN BLEND - HANDMADE BARREL TILE

END OF THIS ACCEPTANCE



NOA No.: 15-1026.03 Expiration Date: 05/09/18 Approval Date: 01/28/16

Page 5 of 5